



TNO Science and Industry
P.O.Box 6235
5600 HE Eindhoven
Netherlands
Not. Lab. 1750

Date: 01-12-2006

EN 12600

Pendulum test – Impact test method and classification for flat glass

Producer: Glaverbel S.A.

Under responsibility of:
Glaverbel S.A.
Div. Processed Glass
Chaussée de la Hulpe 166
B-1170 BRUSSELS
Belgium

Product:

**Planibel
(6 mm)**

Test result (impact: glass side):

1(C)2

The tested samples are **complying** with the requirements of EN12600.

Signature:

E.M. Maan
Project Leader

A.J. Piers, B.Sc.
Programme Leader